



NOTE:

This diagram is for the typical situation i.e. excludes 17a and 18a standard drawings

With a full complement of utilities, the minimum berm width required for street tree planting is 4150 mm.

Without the HT Power or Telecom, the minimum berm width for street tree planting is 3850mm. If the footpath is wider than normal at 1800 mm, the required berm widths are increased to 4700mm and 4400mm respectively with and without HT Power or Telecom Utilities

If these minima cannot be met, Clause 7.3.2.2 applies (i.e. Trees provided in alternative locations).