



NOTES:

1. The sand level in the meter box to be kept below the meter.
2. This gate valve may be omitted when installation is **NOT** made with mains under pressure. On pipes less than 40mm in diameter, a ferrule shall be used in place of the gate valve.
3. In new installations tapping band may be replaced by cut-in tee, tapped gibault or other as directed.
4. Maric or similar approved flow restrictor to be installed in manifold below water meter
5. Laying the pipe in this way provides some flexibility, reducing damage to the watermain fittings if the service pipe is accidentally damaged by trenching work.

Not To Scale